

COUNCIL COMMUNICATION

AGENDA TITLE:

Award Contract for White Slough Water Pollution Control Facility Pond Recirculation

Pump Replacements (\$29,740)

MEETING DATE:

May 3, 2000

PREPARED BY:

Public Works Director

RECOMMENDED ACTION:

That the City Council adopt the attached resolution awarding the contract for the above project to Mechanical Analysis Repair, Inc., of Lodi, in the amount of \$29,739 and appropriate funds in accordance with the recommendation shown below.

BACKGROUND INFORMATION:

This project consists of replacing two 30-year-old electrical motordriven, mixed flow, single stage vertical lift pumps. These pumps are needed to recirculate flows within the storage ponds.

Plans and specifications for this project were approved on April 5, 2000. This is the only bid the City received for this project.

This project was approved at a \$24,000 funding level, which was to be derived from the 1999/2000 Capital Improvement Budget and retiring funds budgeted in the 2000/2001 Capital Improvement Budget. Additional funding will be requested from Wastewater Capital Reserves to cover the bid of \$29,739. This bid exceeded the project estimate due to the age of the original quote and the additional cost of purchasing high-efficiency motors.

FUNDING:

Budgeted Funding:

\$24,000 Wastewater Capital Reserve

Requested Appropriation: \$30,000

Bid Opening Date:

April 20, 2000

Funding Available:

Ruly & Fairth for

Richard C. Prima.

Public Works Director

Prepared by Del Kerlin, Assistant Wastewater Treatment Superintendent

RCP/DK/mk

attachment

Randy Hays, City Attorney

Joel Harris, Purchasing Officer

Fran E. Forkas, Water/Wastewater Superintendent

Del Kerlin, Assistant Wastewater Treatment Superintendent

4/25/00 C:\WINDOWS\TEMP\CCaward.doc

RESOLUTION NO. 2000-66

A RESOLUTION OF THE LODI CITY COUNCIL AWARDING THE CONTRACT FOR WHITE SLOUGH WATER POLLUTION CONTROL FACILITY POND RECIRCULATION PUMP REPLACEMENT, AND APPROPRIATING FUNDS TO COVER THE PROJECT

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened on April 20, 2000 at 11:00 a.m. for White Slough Water Pollution Control Facility Pond Recirculation Pump Replacement, described in the specifications therefore approved by the City Council on April 5, 2000; and

WHEREAS, the City Manager recommends award of the bid for the White Slough Water Pollution Control Facility Pond Recirculation Pump Replacement be made to the sole bidder, Mechanical Analysis Repair, Inc., of Lodi, CA.

NOW, THEREFORE, BE IT RESOLVED by the Lodi City Council that the award of the bid for the White Slough Water Pollution Control Facility Pond Recirculation Pump Replacement, be and the same is hereby awarded to Mechanical Analysis Repair, Inc., of Lodi, CA, the sole bidder, in the amount of \$29,740.00; and

BE IT FURTHER RESOLVED that funds be appropriated as follows:

Wastewater Capital Reserve \$24,000

Dated: May 3, 2000

I hereby certify that Resolution No. 2000-66 was passed and adopted by the City Council of the City of Lodi in a regular meeting held May 3, 2000, by the following vote:

AYES: COUNCIL MEMBERS - Hitchcock, Land, Nakanishi, Pennino

and Mann (Mayor)

JACQUELINE L.¹ Interim City Clerk

NOES: COUNCIL MEMBERS - None

ABSENT: COUNCIL MEMBERS - None

ABSTAIN: COUNCIL MEMBERS - None

2000-66